

1 **(April 3, 2006)**

2 **Submittals**

3 Section 8-01.3(1)A is supplemented with the following:

4

5 Prior to beginning any concrete or grinding work, the Contractor shall submit a
6 plan, for the Engineer's review and approval, outlining the procedures to be used to
7 prevent high pH stormwater or dewatering water from entering surface waters.

8 The plan shall include how the pH of the water will be maintained between pH 6.5
9 and pH 8.5 prior to being discharged from the project or entering surface waters.